

Classification

Number	20-003955-PR06 (NW-H05-05-en-01)
Owner	Afoi Patsala A.E.B.E. Aluminium Systeme 5,5 km Thessaloniki Lagada PO BOX 40405 Thessaloniki Greece
Product	Railing with linear bearing on one side in general accordance to DIN 18008-4 category B
Designation	System: Series 500 Shipping name: 15336
Details	Material Aluminium; Overall dimensions (W x H) 990 mm x 1125 mm; Glass configuration TSG 8 / PVB 1.52 / TSG 8; Thickness 17.52 mm
Special features	-/-

Result **)

Testing the impact resistance of glazing in general accordance with DIN 18008-4:2013-07



**Category B - height of fall 700 mm:
passed**

Basis *)

DIN 18008-4:2013-07

*) and corresponding national versions (e.g. DIN EN)

Test report: 20-003955-PR06 PB-H05-05-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

**) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 8FF-293C9

ift Rosenheim

04.08.2021



Frank Zirbel, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Security/Safety Testing